

Addendum 4 Prescribed Bodies Notifications

An Bord Pleanála (ABP) confirmed in their letter dated 23rd April 2024 that the proposed development (the Proposed Substation as described within the context of the Environmental Impact Assessment) constitutes strategic infrastructure development and that a planning application should be made directly to the Board. A copy of the Board's letter can be found in Addendum 3.

Notification of the submission of the planning application for the proposed development has been sent to the following prescribed bodies (as recommended by ABP in their SID determination correspondence letter referenced above and found in Addendum 3):

- Dept. of Housing, Local Government and Heritage
- Dept. of Environment, Climate and Communications
- Dept. of Agriculture, Food and the Marine
- Dept. of Tourism, Culture, Arts, Gaeltacht, Sport and Media
- Kildare County Council
- Transport Infrastructure Ireland / National Transport Association
- Irish Water
- An Chomhairle Ealaíon
- Fáilte Ireland
- An Taisce
- Heritage Council
- Eastern and Midlands Regional Assembly
- Inland Fisheries Ireland
- Commission of Regulation of Utilities
- Irish Aviation Authority
- Health and Safety Authority
- Office of Public Works
- ESB
- EirGrid

Copies of the notifications are enclosed as part of the application.



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Minister for Housing, Local Government and Heritage
Department of Housing, Local Government and Heritage
Custom House
Dublin
D01 W6X0

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Minister for Climate, Energy and the Environment
Department of Climate, Energy and the Environment
Tom Johnson House
Haddington Road
Dublin 4
D04 K7X4

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.
- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Minister for Agriculture, Food and the Marine
Department of Agriculture, Food and the Marine
Agriculture House
Kildare Street
D02 WK12

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Minister for Tourism, Culture, Arts, Gaeltacht, Sport and Media
Department of Tourism, Culture, Arts, Gaeltacht, Sport and Media
Leeson Lane
Dublin
D02 R5Y3

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Kildare County Council
Head Office Áras Chill Dara
Devoy Park
Naas
Co Kildare
W91 X77F

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.

- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.
- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

Transport Infrastructure Ireland / National Transport Association
Parkgate Business Centre
Parkgate Street
Dublin 8
D08 DK10

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Irish Water
PO Box 860
South City Delivery office
Cork City
T12 C825

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

An Chomhairle Ealaíon
70 Merrion Square
Dublin 2
D02 NY52



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

Failte Ireland
88 - 95 Amiens Street
Dublin 1
D01 WR86



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

An Taisce
Tailors' Hall
Back Lane
Dublin 8
D08 X2A3



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

The Heritage Council
Áras na hOidhreachta
Church Lane
Kilkenny
R95 X264



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Eastern and Midlands Regional Assembly
3rd Floor North
Ballymun Civic Centre
Main Street Ballymun
Dublin 9
D09 C8P5

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.
- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

Inland Fisheries Ireland
3044 Lake Drive
Citywest Business Campus
Dublin
D24 CK66



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

CRU Customer Care Team,
Commission of Regulation of Utilities
PO Box 11934
D24 PXW0



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

Irish Aviation Authority
The Times Building
11-12 D'Olier Street
Dublin 2
D02 T449

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl



DESIGNING AND DELIVERING
A SUSTAINABLE FUTURE

Health and Safety Authority
The Metropolitan Building
James Joyce Street
Dublin 1
D01 K0Y8

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

Office of Public Works
Jonathan Swift Street
Trim, Co Meath
C15 NX36



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie

www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan

Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

ESB
Sarsfield Rd
Wilton, Cork,
T12 E367



Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

Cork: Core House,
Pouladuff Road,
Cork, T12 D773,
Ireland

T: +353 21 496 4133
E: info@ftco.ie
www.fehilytimoney.ie

Directors: Sinéad Timoney | Bernadette Guinan | Jim Hughes | Ray O'Dwyer
Company Secretary: Dave O'Regan
Registered in Ireland, Fehily Timoney & Company Ltd. Number 180497
Registered Office: Core House, Pouladuff Road, Cork, Ireland.
VAT Registration Number: IE6580497D



- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl

EirGrid
The Oval, 160 Shelbourne Road,
Ballsbridge
Dublin 4
D04 FW28

Our Ref: P22-242/Lett/BC/CC/KB

18 June 2025

Strategic Infrastructure Development (SID) Planning Application for the development of a 110kV Substation within the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid, Co. Kildare

Dear Sir/Madam,

On behalf of our client, North Kildare Wind Farm Limited, we are submitting a Planning Application for a Strategic Infrastructure Development (SID) to An Bord Pleanála (ABP). In its letter dated 23rd April 2024, ABP confirmed that the Board is of the opinion that the proposed development constitutes SID and therefore the planning application should be made directly to the Board. In that letter, the Board provided a list of prescribed bodies to be consulted. Your organisation was on this list and therefore we are providing you with this letter and copies of the planning application documents for your consideration.

The proposed development will constitute the provision of the following:

- Construction of a 110 kV Substation and associated works within the townland of Coolree. The Substation includes a total compound footprint of 1.32 hectares. , enclosed by palisade fencing. The Substation Compound will include :
 - 1 No. single storey substation control building (450 m2);
 - 1 No. single storey customer MV Building (160 m2);
 - Switchgear, Arc Suppression Coil, Cable Sealing Ends, Cable Chair, Circuit Breakers, Current Transformers, Disconnects, Post Insulators, Surge Arrestors, Grid Code Compliance Equipment and Voltage Transformers; and all associated ancillary works necessary to facilitate the development;
 - 9 No. lightning masts to a height of 20 m;
 - 2.6m high palisade guard railing with perimeter boundary fencing will be erected around the periphery of the compound for security and protection measures;
 - Lighting will be provided by 9 no. lighting columns, approximately 3m in height as well as exterior wall mounted lights on the control buildings.
- Erection of 2 no. line-cable interface masts to enable a loop-in/loop-out connection to the existing Kinnegad-Rinawade 110 kV overhead line. The steel lattice masts will extend to heights of 16m above existing ground level.

- Laying of 110 kV underground cabling between the proposed substation and the proposed loop-in/loop-out masts.
- Permanent access road (ca. 7.3 km in length) which traverses the townlands of Ballynamullagh, Kilmurry, Coolree, Killyon and Drehid to allow access to the substation including a short spur (ca. 0.9 km) off the main access track to access the 2 no. line-cable interface masts. The entrance to the local road (L5025) will be shared with the proposed Drehid Wind Farm.
- 3 no. Stream Crossings.
- Associated construction works and drainage infrastructure.
- Peat deposition area immediately adjacent to the proposed substation.

The development subject of this application will facilitate the connection of the proposed 11 no. wind turbine Drehid Wind Farm (the 'Proposed Wind Farm') to the national electricity grid. A planning application for the Proposed Wind Farm development is also being lodged to An Bord Pleanála.

An Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) have been prepared in relation to the project and accompany this planning application.

The planning application, Environmental Impact Assessment Report (EIAR) and Natura Impact Statement (NIS) may be inspected free of charge or purchased on payment of a specified fee (which fee shall not exceed the reasonable cost of making such copy) during public opening hours for a period of seven weeks commencing on 26th June 2025 at the following locations:

- The Offices of An Bord Pleanála, 64 Marlborough Street, Dublin 1
- Planning Department, Áras Chill Dara, Devoy Park, Naas, Co. Kildare, W91X77F

The application may also be viewed /downloaded on the following website:
www.drehidsubstationSID.ie

In considering this application, An Bord Pleanála can decide to:

- a) grant the permission/approval, or
- b) make such modifications to the proposed development as it specifies in its decision and grant permission/approval in respect of the proposed development as so modified, or
- c) grant permission/approval in respect of part of the proposed development (with or without specified modifications of the foregoing kind), and any of the above decisions may be subject to or without conditions, or
- d) Refuse permission to grant the permission/approval.



Any submissions or observations may be made only to An Bord Pleanála, 64 Marlborough Street, Dublin 1 relating to:

- a) The implications of the proposed development for proper planning and sustainable development, and
- b) The likely effects on the environment of the proposed development, and
- c) The likely significant effects of the proposed development on a European site, if carried out.

Any enquiries relating to the application process should be directed to the Strategic Infrastructure Development Section of An Bord Pleanála (Telephone: 01 8588100).

Any submissions/observations must be received by the Board not later than 5.30 p.m. on the 14th of August 2025.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'Brian Cronin', is written over a horizontal line.

Brian Cronin
for and on behalf of **Fehily Timoney and Company**

Encl